




State of Ohio Environmental Protection Agency

Northeast District Office
2110 E. Aurora Road
Twinsburg, Ohio 44087
(216) 425-9171



Richard F. Celeste
Governor

January 19, 1990

Mr. William Lacure
Environmental Control Coordinator
The Timken Company
General Offices
Canton, Ohio 44706-1798

Dear Mr. Lacure:

I have several comments concerning my recent visit on January 17, 1990.

- * Additives must be approved by the Ohio EPA as stated in Part II of the NPDES permit. Mr. Raj Chakrabarti of the Central Office/ Division of Water Pollution is the person to contact concerning any approvals.
- * The Industrial Permits Group does not object to the proposed additions to outfall 001. The Cold Rinse tank will become an internal outfall 601. Monitoring parameters will be established as indicators of excess carryover. As previously stated, additives to the boilers and condensate tanks must be approved by the Central Office. Other discharges must be approved by this office.
- * The renewal permit will be more complex than the previous one. With the addition of the 10,000 gpd package plant, Timken will have a total of four monitoring stations. I am enclosing a copy of my Timken water flow diagram, please respond with any comments.

I will send a copy of the draft permit as soon as it is finished.

If you have any questions, please call me.

Sincerely,

William J. Zawiski
Environmental Scientist
Industrial Permits Group

WJZ:mjo

Enclosure

